



## 2019 ANNUAL DRINKING WATER QUALITY REPORT

**PWSID #:** 5030006

**NAME:** Manor Township Joint Municipal Authority

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

### **WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Field Crew Leader, Ian Ferguson at 724-763-2511. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the third Wednesday of each month at 6:30 pm at the Authority Office, 2310 Pleasant View Drive, Ford City, PA 16226

### **SOURCE(S) OF WATER:**

Our water source(s) are four (4) ground water wells drawing water from the Allegheny Glacial Outwash Aquifer:

MTJMA has completed, with the PA DEP, a formal Wellhead Protection Program. The Wellhead Protection Steering Committee has updated the potential contaminant inventory list and the hydrogeologist has delineated the well source waters. The plan was adopted in 2014.

A Source Water Assessment of our source(s) was completed by the PA Department of Environmental Protection (Pa. DEP). The Assessment has found that our sources are potentially most susceptible to accidents in the transportation corridor with the release of petroleum product, heavy metals & compounds in transit. Overall, our sources have high risk of significant contamination. A summary report of the Assessment is available on the **Source Water Assessment Summary Reports eLibrary web page: [www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045](http://www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045)**. Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP Northwest Regional Office, Records Management Unit at (814) 332-6945

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

### **MONITORING YOUR WATER:**

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2019. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

**DEFINITIONS:**

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Minimum Residual Disinfectant Level (MinRDL)* - The minimum level of residual disinfectant required at the entry point to the distribution system.

*Level 1 Assessment* – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

*Level 2 Assessment* – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

*Treatment Technique (TT)* - A required process intended to reduce the level of a contaminant in drinking water.

*Mrem/year* = millirems per year (a measure of radiation absorbed by the body)

*pCi/L* = picocuries per liter (a measure of radioactivity)

*ppb* = parts per billion, or micrograms per liter (µg/L)

*ppm* = parts per million, or milligrams per liter (mg/L)

*ppq* = parts per quadrillion, or picograms per liter

*ppt* = parts per trillion, or nanograms per liter

**DETECTED SAMPLE RESULTS:**

<b>Chemical Contaminants</b>								
Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Antimony	6	6	0.4	N/A	ppm	10/15	N	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Nitrate	10	10	1.36	N/A	ppm	10/19	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
HAA5	60	N/A	15.1	N/A	ppb	8/19	N	By-product of drinking water disinfection
TTHMs	80	N/A	68.9	N/A	ppb	8/19	N	By-product of drinking water disinfection
Chlorine	MRDL = 4	MRDLG = 4	0.96	0.58 - 0.96	ppm	12/19	N	Water additive used to control microbes

<b>Entry Point Disinfectant Residual</b>							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	0.60	0.0	0.0 - 1.41	ppm	7/14/19	N	Water additive used to control microbes.

<b>Lead and Copper</b>							
Contaminant	Action Level (AL)	MCLG	90 <sup>th</sup> Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	1.12	ppb	0 of 20	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.07	ppm	0 of 20	N	Corrosion of household plumbing.

<b>Microbial (related to Assessments/Corrective Actions regarding TC positive results)</b>					
<b>Contaminants</b>	<b>TT</b>	<b>MCLG</b>	<b>Assessments/ Corrective Actions</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Total Coliform Bacteria	Any system that has failed to complete all the required assessments or correct all identified sanitary defects, is in violation of the treatment technique requirement	N/A	See detailed description under "Detected Contaminants Health Effects Language and Corrective Actions" section	N	Naturally present in the environment.

**DETECTED CONTAMINANTS HEALTH EFFECTS LANGUAGE AND CORRECTIVE ACTIONS:**

N/A

**OTHER VIOLATIONS:**

We monitored and recorded our Entry Point Disinfection Residual but failed to report the results to DEP in the proper amount of time. We have submitted these results to DEP to return to compliance.

**EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

### **Information about Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Manor Township Joint Municipal Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the *Safe Drinking Water Hotline* or at <http://www.epa.gov/safewater/lead>.

### **OTHER INFORMATION:**

MTJMA had no detections of Volatile Organic Compounds or Synthetic Organic Compounds. MTJMA completed all the required monitoring for Total Coliform Bacteria and none was detected. Therefore, no tests for E. coli were required. Although the lowest value for the entry point disinfection residual was below the 0.60 level, it was less than 4 hours and therefore, no violation occurred.

The MTJMA Board & Field Crew Leader would like to remind all customers of the following:

- The meter change-out program continues – customers are encouraged to contact the MTJMA Office at 724-763-2511 to schedule appointments. There is no fee for the change-out, however please note that regulators (if needed) are required prior to the meter and are the responsibility of the property owner.
- Please keep your emergency shut-off valve (curb box) area visible and free from obstructions – trees, shrubs, fences and overgrowth
- The Authority website [mtjma.com](http://mtjma.com) has a customer portal that permits a customer to view account information, pay bills via electronic payment (ACH=no fee, credit and debit cards small fee), eliminate paper bills, and get e-bills. Separately, automatic deductions from your checking account can be set-up with the office for payment just before the due date with no fee. Also, various MTJMA forms and instructions can be found on the website.

This report is no longer mass distributed by mail according to DEP guidance. If you do not have access the web a copy of this report is available to be picked up at the MTJMA Office. Thank you for understanding this decision to save our ratepayers in the production, printing and mailing costs of this required report.

[www.mtjma.com/ccr2019](http://www.mtjma.com/ccr2019)  
<http://GoH2o.net/MTJMA/ccr>